



Fire Life Safety

777 Sawgrass Corporate Pkwy. - Sunrise, FL 33325 - P: 954.746-3470 - F: 954.746.3455

How to Obtain a Fire Inspection RE: Occupational License

1. Fire Extinguisher (minimum size: 2A10BC) tagged by a fire extinguisher company:
 - One fire extinguisher for every 2,500 square feet.
 - One fire extinguisher for every 50 feet of travel distance (for every exit/entrance).
2. If you have illuminated exit/emergency lights, they must be working.
3. Address should be on all doors.
4. There should be four to five feet of aisle space minimum to all egress doors.
5. Business must be set up as if ready to open.
6. Carpet “specs” indicating the “radiant Flux” or “Class” – RE: the National Fire Protection Association (NFPA 253). This is needed for new carpeting only.
7. Other requirements may be necessary based on occupancy type.

Please call (954) 746-3470 with any questions.